

## Kelly, Shaheerah

---

**From:** Kelly, Shaheerah  
**Sent:** Thursday, October 24, 2013 2:05 PM  
**To:** Eric Albright; Shane Young  
**Subject:** SPI Monitoring

The PSD permit currently requires CEMS for NOx, CO and CO2. In addition to this requirement, we will likely require a 12% CO2 correction for ppmv calculations of NOx and CO. Please let me know if you have any questions about this.

\*\*\*\*\*

Shaheerah Kelly  
U.S. Environmental Protection Agency, Region 9  
Permits Office, Air Division  
San Francisco, CA 94105  
Phone: 415-947-4156  
Fax: 415-947-3579  
Email: [kelly.shaheerah@epa.gov](mailto:kelly.shaheerah@epa.gov)